

23rd July 2014

With reference to the clarification visit held at the Xaghra Parvis please find the following clarifications:

1 - The person holding Licence B must be present whenever the engineer requests a site meeting, during testing and commissioning. Any other time to be planned by the licence B holder provided that the electrical installation is erected according to the tender specifications.

2 - Specification 3.11.1 Enclosure and Door shall read the following; **Either Stainless Steel / Polycarbonate / Glassfibre Reinforced Polycarbonate / Polyester / Acrylnitrile-butadiene-styrene / Fibreglass / Die Cast Aluminium.**

The other specification **Minimum Dimensions:** 250mm x 250mm x 200mm (H x L x W), **Maximum Dimensions:** 350mm x 300mm x 250mm (H x L x W), **Ingress Protection:** IP66 or better, **Housing Protection:** IK10, **Temperature range:** -15°C to 80°C must be adhered to.

3 - Any light fitting that falls within a positive tolerance of six percent (+6%) of the maximum dimensions specified on the tender document shall be accepted for this tender document.